

## Instrument used for inspection and calibration:

Vibration Meter

type: Adash A4404, Czech Republic

s.n.: 624370

Instrument is traceable to Primary Laboratory of Czech Institute of Metrology. Calibration certificate nr. 6011-KL-L0527-13 is possible to provide on demand (Czech language only).

Uncertainties:

reference frequency definition 1.10<sup>-3</sup> acceleration measurement 1.5 %

Uncertainties were calculated according to EA-4/02 document.

Inspection conditions:

Air temperature 22 °C ± 2 °C, rel. humidity 50 % ± 10 %

